

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190115-E180220  
**Report Reference** E180220-20180924  
**Issue Date** 2019-JANUARY-15

**Issued to:** HORNER APG L L C  
59 S STATE AVE  
INDIANAPOLIS IN 46201-3876

**This certificate confirms that  
representative samples of**

PROGRAMMABLE CONTROLLERS FOR USE IN  
HAZARDOUS LOCATIONS  
See Addendum for Models

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 121201 & CAN/CSA C22.2 No. 213-17, Nonincendive  
Electrical Equipment for Use in Class I and II, Division 2  
and Class III, Divisions 1 and 2 Hazardous (Classified)  
Locations  
UL 61010-1 & CSA C22.2 No. 61010-1-12, Safety  
Requirements for Electrical Equipment for Measurement,  
Control, and Laboratory Use - Part 1: General  
Requirements


**Additional Information:**

See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190115-E180220  
**Report Reference** E180220-20180924  
**Issue Date** 2019-JANUARY-15

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Class I, Div. 2 Groups A, B, C, D; Class II, Division 2, Groups F and G; Class III Hazardous Locations.

X2 Operator Control Stations Series – Models HE-X2A and HE-X2R, may be followed by two or three additional alphanumeric characters.

X4 Operator Control Stations Series – Models HE-X4A and HE-X4R, may be followed by two or three additional alphanumeric characters.

X7 Operator Control Stations Series – Models HE-X7A and HE-X7R, may be followed by two or three additional alphanumeric characters



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

